



Install Date:	April 2008	By:	Crostex Construction
Inspection Date	10/26/2011	Prep:	Site was blasted and primed using VF30
Product:	H2S Safe	Substrate:	Pre-Cast Concrete
Location:	618 Moss Hammock, Sugarland TX		
Feature of test:	Sanitary manhole was lined using H2S Safe, the purpose of the test was to prove durability over a 3 year period.		

Photos:



Results:	The holes were inspected and did not show any delimitation from the substrate. Only discoloring of the coating was present.
----------	---